



# TEST REPORT

1. NO : CT17-029693

2. Client

○ Name : KyungDong One Co., Ltd

○ Address : 1095, Cheongang-ro, Gangdong-myeon, Gyeongju-si, Gyeongsangbuk-do, Korea

3. Date of Test : 2017.02.28 ~ 2017.04.24

4. Use of Report : Quality Management

5. Test Sample : Granule stone coated metal roofing tile

6. Test Method


(1) KS F 4751:2004

7. Test Results

1) Granule stone coated metal roofing tile

Test Item(s)	Unit	Test Method	Test Results	Remark
Resistnace to humidity (500 h)	-	(1)	Pass	(49±1) °C, Rh=(95±5) % 이상

---- End of Report ----

Affirmation	Tested By	L. M. H.	Technical Manager	
	Name : Lee Min Hong		Name : Kim Jae Yeon	
Our report apply only to the standards or procedures identified and to the sample(s) tested unless otherwise specified. The test results are not indicative of representative of the qualities of the lot from which the sample was taken or of apparently identical or similar products.				

2017.04.24

Korea Conformity Laboratories

President Kyung Sik Kim

*Kyung Sik Kim*

Address : 42639 39, Jukjeon 1-gil, Dalseo-Gu, Daegu ,Korea 82-53-557-6681

Result Inquiry : Daegu & Gyeongbuk Branch 82-53-557-6681

