



TEST REPORT

98, Gyoyukwon-ro, Gwacheon-si, Gyeonggi-do, 13810, Korea

TEL 82-41-589-0010

FAX 82-41-589-0012

Report No : TAK-2018-038459

Receipt Date : 2018.03.06.

Representative : Sohn Yeonho, Roh Yeonsang

Test Completion Date : 2018.04.04.

Company name : KYUNG DONG ONE Co., Ltd.

Address : (Yeouido-Dong), 22, Gukhoe-daero 76-gil, Yeongdeungpo-gu, Seoul, Korea

Sample name : Water repellent heat insulator made of perlite-Type2 (Hyperlite)

Test Results

TEST ITEM	UNIT	SAMPLE	RESULT	TEST METHOD
Thermal Conductivity[Average Temperature (70±5) °C]	W/m · K	-	0.046	KS L 9016 : 2010(By Means of Heat Flow Meter Apparatus)

- Usage of Report : QUALITY CONTROL

- Note :
1. The test results of this test report are only limited in to the samples and sample names provided by the client and do not guarantee the quality of all products of the client. You Can check website (www.ktr.or.kr) or QR code to verify the authenticity of the certificate.
 2. This test report shall be used only within the purpose of its defined usage and shall not be used fo public relation, advertisement and lawsuit.
 3. This test report is olny valid when printed on KTR original report paper with hologram and when re-issued by KTR. The copy and the electronic file of the test report are only for reference.

Park Joo-ick

Prepared by Park Joo-ick

E-mail:jooick@ktr.or.kr

You Seok

Reviewed by You Seok

Tel : 1577-0091(ARS ①→④)

2018.04.04

Korea Testing & Research Institute

President

Byun, Jong-Rip

QR Code for forgery